

NOTES:

- 1. PRECAST REINFORCED CONCRETE TOPS, RISERS, BASES AND REBARS SHALL CONFORM TO LATEST ASTM C-478 STD. SPECIFICATIONS.
- 2. INTERIOR AND EXTERIOR OF MANHOLE SHALL BE COATED IN ACCORDANCE WITH SECTION 02555 OF CITY OF SAVANNAH STD. SPECIFICATIONS.
- 3. MANUFACTURER CERTIFICATION THAT MANHOLE MEETS ASTM SPECIFICATION SHALL BE SUBMITTED TO CITY OF SAVANNAH.
- 4. FOR MANHOLE RING AND COVER, SEE DETAIL S10.
- 5. FOR MANHOLE STEPS SEE DETAIL S15. STEPS TO BE INSTALLED IN A VERTICAL ROW ON 16" CENTERS.
- 6. CHECK FOR BUOYANCY
- 7. ALL PIPE PENETRATIONS SHALL HAVE A BOOT CONNECTION IN ACCORDANCE WITH DETAIL S12

STANDARD PRECAST CONCRETE MANHOLE

STANDARD CONSTRUCTION DETAILS



SCALE: N.T.S.

DATED: SEP 2013

PLATE NUMBER:

S1